

# APPLICATION FOR INSTALLATION OF SMALL SCALE EMBEDDED ELECTRICITY GENERATION



Work Order No: \_\_\_\_\_

File Reference: 16/2/1

This application form for the connection of small scale embedded generation is for small scale embedded generators to be installed by residential, commercial or industrial customers. It is applicable to all forms of embedded electricity generation, including renewable energy and cogeneration.

- A separate "Electricity Supply Agreement" form must also be completed, except for installations where reverse power blocking is to be installed.
- If the embedded generator is to be configured as a standby supply after islanding from the municipal electrical grid, the generator will have to be connected to the existing internal wiring of the property. In such a case, the property owner must obtain a certificate of compliance from a qualified electrician and complete COMMISSIONING REPORT as per appendix 3.

New Installation	Revised application	System upgrade	Change of ownership
Other: (specify)			
Erf No:	Township/Ward	Account No:	
Initials & Surname:	Title:		
Postal Address:	E-mail address :		
	Postal Code:	Fax No:	
Street (Physical) Address / Location:	VAT Registration No:		
Contact No: Home	Work	Cell phone	
Indicate: Residential	Business	Industrial	Group development
Other: (e.g. farm – specify)			

**Planned construction schedule:**

Projected construction start date	
Projected commencement date	

**Motive for small scale embedded generation:** (Tick appropriate box)

Energy to be used for own electricity grid and no excess to be exported to municipal electrical grid.	Energy to be used for own electricity grid and excess to be exported to municipal electrical grid.	Energy to be used solely for exporting to municipal electrical grid.	Energy to be used for wheeling to third party through municipal electrical grid.
---	--	--	--

**Type of generation:** (Tick appropriate box)

Photo-voltaic	Concentrated Solar Power	Small Hydro	Landfill Gas	Bio-mass	Bio gas	Wind	Co-generation	Fossil fuel generation
Expected Life of Embedded Generation Project _____ years								

**Battery storage:**

No	Yes	kWh
----	-----	-----

**Type of energy conversion:** (Tick appropriate box and include operating characteristics).

Synchronous generator	Asynchronous /Induction generator	Inverter	Fuel-cell	Dyno set
-----------------------	-----------------------------------	----------	-----------	----------

**Site location:**

Latitude(dd mm sss)	S	°	'	"	"
Longitude(dd mm sss)	E	°	'	"	"

For commercial/industrial only (show location and dimensions of intended installation infrastructure in relation to the existing property point of connection and buildings.)	

**Site land use zoning:**

(Attach copy of zoning certificate)

--

**Preliminary design<sup>1</sup>:**

(to be attached)

Circuit diagram & design showing major components, proposed point of common coupling, isolating & interfacing devices with municipal grid, protection schemes, customer grid, operating characteristics.
--

<sup>1</sup> For guidance here, it is recommended that an installer/supplier be consulted.



**Protection Details:** (Attach data sheets)

Method of synchronizing: (Auto/Manual, make and type of relay etc.)	
Method of anti-islanding: (Details of scheme, relays to be used etc.)	
Method of generator control: (AVR, speed, power, PF etc. , relays to be used)	
Other protection to be Applied: (O/C, E/F, over/under voltage, over/under frequency, reverse power etc.)	

**Intended Recipient of Embedded Generation Output:**  
(Own use, Overstrand Municipality Electricity Consumer, Overstrand Municipality Electricity)

Recording of quality of supply devices	

**List of regulatory approvals, requirements and normative references<sup>3</sup>:** (Tick appropriate box or mark not applicable N/A)

Electricity Regulation Act, Act 4 of 2006 and Electricity Regulation Amendment Act, Act 28 of 2007	
Occupational Health & Safety Act, No. 85 of 1993 as amended	
South African Distribution Code (all parts)	
South African Grid Code (all parts)	
South African Renewable Power Plants Grid Code	
Overstrand Municipality Electricity Supply By-Law	
SANS 474 / NRS 057: Code of Practice for Electricity Metering	
SANS 10142- Parts 1 to 4: The wiring of premises (as amended and published)	
NRS 048: Electricity Supply – Quality of Supply	
NRS 097-1 : Code of Practice for the interconnection of small scale embedded generation to electricity distribution networks: Part 1 MV and HV	
NRS 097-2 : Grid interconnection of small scale embedded generation: Part 2: Small scale small scale embedded generation	

**Clearance by other Municipal departments**

FUNCTION	SECTION	COMMENTS	NAME	SIGNATURE	DATE
Zoning/subdivision	Town Planning				
Building structure plans	Building Department				
Noise impact & air pollution	Environmental Services				

Note:

- Electricity Services will require **prior** approval from these departments. Applications to connect to the municipal electrical grid will not be considered until all relevant approvals have been obtained.
- Photovoltaic (PV) SSEG applications will require approval from only Town Planning and Building Departments if:
  - Roof top installations: PV panel(s) in its installed position projects more than 1.5m, measured perpendicularly, above the roof and/or projects more than 600mm above the highest point of the roof;
  - Installations on the ground: PV panel(s) in its installed position projects more than 2.1 metres above the natural/finished ground level.

<sup>3</sup>Note: It is the responsibility of the ECSA registered professional engineer/technologist to ensure compliance through their professional sign-off of the installed system in Appendix 1 – SSEG Installation Commissioning Report.

## Installer Details

Installer:			
Accreditation/qualification:			
Professional registration:		Reg. No.	
Address:			Postal code:
Contact person:			
Telephone no:	Work:	Cell:	
Fax:		E-mail address:	
Additional Comments			

Signed ( Installer): \_\_\_\_\_ Date: \_\_\_\_\_

(Note: Sign-off by an ECSA registered professional is optional at application stage, however it is recommended that an ECSA registered professional engineer or professional technologist that is familiar with the technical details of the intended generation technology, complete this application form)

ECSA registered professional	Name & Surname	Registration number:	Registration category:

Additional Comments	

Signed ( ECSA registered professional): \_\_\_\_\_ Date: \_\_\_\_\_

I request the Overstrand Municipality Electro Technical Department to proceed with the review of this small scale embedded generation interconnection application. I understand that:

- I will have to pay for both in-house and outsourced engineering studies conducted as part of this review, should these be required; and
- A quotation for such work will be provided beforehand, giving me the opportunity to cancel or modify the application should I wish to do so.

I further consent to Overstrand Municipality providing this information to the National Transmission Company and other Distributors as required.

Application completed by:	Name & Surname:	Title:

Signed (Applicant): \_\_\_\_\_ Date: \_\_\_\_\_

Signed ( Property Owner): \_\_\_\_\_ Date: \_\_\_\_\_

Submit completed form to: Electro Technical Department

## FOR OFFICE USE

Date Application Received:				Application Reference No:	
Further Information Required: (e.g. Competent Person detail required i.t.o. Occupational Health and Safety Act, General Machinery Regulations: Supervision of Machinery, Section 2)	YES		NO	Date Received:	
Load Flow Analysis Required:	YES		NO	Date Complete:	
Fault Level / Protection Grading Study Required:	YES		NO	Date Complete:	
Approved in Principle:	YES		NO	Date Applicant Advised:	
Copy of COC received:	YES		NO	Date COC received:	
Installation inspected by Municipality:	YES		NO	Date inspected:	
Smart meter installed and programmed:	YES		NO	Date installed and programmed:	
Installation certified for commissioning:	YES		NO	Date applicant informed that installation may be commissioned:	

Installation inspected by: Electrician (Name): \_\_\_\_\_ Staff no: \_\_\_\_\_

Signature Electrician: \_\_\_\_\_ Date: \_\_\_\_\_

## ANNEXURE A

<b>Responsibilities of Embedded Generators to Overstrand Municipality, Electro Technical Department</b>	
1	The Embedded Generator shall enter into a connection agreement with Overstrand Municipality Electricity (Distributor) before connecting onto the Distribution System.
2	The Embedded Generators shall ensure that the reliability and Quality of Supply complies with the terms of the connection agreement.
3	The Embedded Generator shall comply with the Distributor's protection requirement as well as protection of own plant against abnormalities, which could arise on the Distribution System.
4	The Embedded Generator shall be responsible for any dedicated connection costs incurred on the Transmission System or Distribution System as a result of connection of the Embedded Generation facility to the Distribution System.
5	The Embedded Generator shall be responsible for synchronizing the generating facility to the Distribution System within pre-agreed settings.
<b>Connection Point Technical Requirements</b>	
1	The Embedded Generator shall be responsible for the design, construction, maintenance and operation of the equipment on the generation side of the connection point.
2	The Embedded Generator shall be responsible for the provision of the site required for the installation of the Distributor's equipment required for connecting the generating facility.
3	The technical specifications of the connection shall be agreed upon by the participants based on the Distribution System Impact Assessment Studies.
4	A circuit breaker and visible isolation shall be installed at the connection point to provide the means of electrically isolating the Distribution System from the generating facility.
5	The Embedded Generator shall be responsible for the circuit breaker to connect and disconnect the generator plant.
6	The location of the circuit breaker and visible isolation shall be decided upon by the participants.
<b>Protection Requirement for Embedded Generators</b>	
<b>General Protection Requirements</b>	
1	The Embedded Generator's protection shall comply with the requirements of Overstrand Municipality.
2	Additional features including inter-tripping and generator plant status to be agreed upon by the participants.
3	The protection schemes used by the Embedded Generator shall incorporate adequate facilities for testing and maintenance.
4	The protection scheme shall be submitted by the Embedded Generator for approval by Overstrand Municipality Electro Technical Department.
<b>Specific Protection Requirements</b>	
1	<b>Phase and Earth Fault Protection</b> (a) The protection system of the Embedded Generator shall fully coordinate with the protective relays of the Distribution System. (b) The Embedded Generator shall be responsible for the installation and maintenance of all protection relays at the connection point.
2	<b>Over/under Voltage and over/under Frequency Protection</b> The Embedded Generator shall install over/under voltage and over/under frequency protection to disconnect the generating facility under abnormal network conditions as agreed between the Distributor and the Embedded Generator.
3	<b>Faults on the Distribution System</b> The Embedded Generator shall be responsible for protecting its generation facility in the event of faults and other disturbances arising on the Distribution System.
4	<b>Islanding</b> (a) The Embedded Generation facility shall be equipped with loss of mains detection protection system to prevent the generator from being connected to a de-energized Distribution System. The Distributor shall take reasonable steps to prevent closing circuit breakers onto an islanded network. (b) For unintentional network islanding, the Embedded Generator and the Distributor shall agree on methodology for disconnecting and connecting the Embedded Generator.

Quality of Supply Requirements	
1	<b>Frequency Variations</b> The Embedded Generation facility shall remain synchronized to the Distribution System while the network frequency remains within the agreed frequency limitations at all time.
2	<b>Power Factor</b> The power factor at the connection point shall be maintained within the limits agreed upon by Overstrand Municipality Electro Technical Department.
3	<b>Fault Levels</b> The Embedded Generator shall ensure that the contractually agreed fault level contribution from the generation facility shall not be exceeded at any time.
<b>Telemetry</b>	
1	The Embedded Generator shall have the means to remotely report any status change of any critical function that may negatively impact on the Quality of Supply of the Distribution System.
<b>Operational Responsibilities of Embedded Generators</b>	
1	The Embedded Generator shall ensure that its generating units are operated within the capabilities defined in the Connection Agreement entered into with the Distributor.
2	The Embedded Generator shall reasonably cooperate with the Distributor in executing all the operational activities during an emergency generation condition.
3	The Embedded Generator shall assist the Distributors in correcting Quality of Supply problems caused by its equipment connected to the Distribution System.
4	All customers must declare any co-generating plant (whether licensed or not) and specify the interlocking mechanism to prevent inadvertent parallel operation with the Distributor's network.
5	Embedded Generators shall have the required protection to trip in the event of a momentary supply loss causing an island condition to prevent paralleling out of synchronism due to auto-reclose functionality on the Distributor's Network.
<b>Fault Reporting and Analysis/Incident Investigation</b>	
1	The Embedded Generators shall report the loss of generation (as agreed by the participants) to the Distributor within 15 minutes of the event occurring. Notice of the intention to reconnect such shall be given with at least 15 minutes advance notice to enable the Distributor to take any necessary action required.
<b>Outage Scheduling and co-ordination</b>	
1	Embedded Generators with the maximum capacity greater than 1MW shall furnish the Distributor with information on planned outages in order for the Distributor to properly plan, and coordinate its control, maintenance and operation activities.
<b>Standards to abide by</b>	
1	NRS 097 :GRID INTERCONNECTION FOR EMBEDDED GENERATION
2	NRS 048 :ELECTRICITY SUPPLY: QUALITY OF SUPPLY
<b>Additional Requirements</b>	
1	Where the 11 kV side of the generator transformer is Star, an NER must be fitted.
2	Where the 11 kV side of the generator transformer is Delta, an NECR must be fitted.