

										Note: The inverter has single-phase mains surveillance and is not able to communicate with each other to detect an out-of-bound voltage on all three phases. According to NRS 097-2-1 an external three phase mains surveillance unit is necessary for installations above 3 kW to detect an out-of-bound voltage condition on a three phase system. The inverter is intended to be used for single phase installations only.
Voltronic	Maand	Hybrid PV inverter grid-tied	Bureau Veritas	2016/09/14	2019/12/31	PVZA160624N005	U16-0520	Yes	No	
Voltronic	InfiniSolar E 5.5kW	Hybrid PV inverter grid-tied	Bureau Veritas	2017/03/27	2019/12/31	PVZA170301N060	U17-0125	Yes	No	
Voltronic	InfiniSolar 10k	Hybrid PV inverter grid-tied	Bureau Veritas	2015/12/15	2019/12/31	PV151102N012-NRS 097-2-1	U15-0470	Yes	No	
Ziehl	UFR1001E relay	Network & system relay	Bureau Veritas	2018/06/07		11TH0501-NRS 097-2-1 1	U18-0308	No	Yes	Network and system grid protection voltage and frequency relay only.

RCMU - residual current monitoring unit

RCD - residual current device

RCM - residual current monitoring

SPD - surge protection device

Notes:

1. The City shall not incur any liability of any nature whatsoever arising out of the publication by it of this list, or arising out of the selection by the user of a particular device. This includes liability for any losses incurred as a result of safety issues or negligence relating to the design, construction, installation, commissioning, operation and maintenance of any device listed on the list.
2. This list is for information purposes only and the use thereof as a guideline for the selection of a device is at the sole risk of the user.
3. The City does not guarantee the functionality or suitability of any device listed on the list.
4. NRS 097-2-1: 2010 type test certification on this list is accepted until 31 December 2019. The commissioned inverter settings shall be in accordance with the new NRS 097-2-1: 2017 version.
5. All the existing NRS097-2-1: 2010 type tested inverters/equipment on this list must be SANAS re-certified in accordance with NRS097-2-1: 2017 with effect from 1 January 2020, if the inverter/equipment is considered for an embedded generation application.
6. Type testing certifications for inverters that must be added to this list, shall be in accordance with latest NRS 097-2-1, currently 2017 version.
7. All grid-tied hybrid inverters shall be equipped with a separate suitably interlocked change-over switch if interlocked with the grid as specified in the Requirements for small scale embedded generation (SSEG) document.

[http://teamsites.capetown.gov.za/sites/esprotelmeas/SitePages/Home/.aspx/reference/ryno/vorms/Approved inverter and equipment to NRS 097-2-1](http://teamsites.capetown.gov.za/sites/esprotelmeas/SitePages/Home/.aspx/reference/ryno/vorms/Approved%20inverter%20and%20equipment%20to%20NRS%20097-2-1)
2019 10 08